



Testing. Advising. Assuring.

| | | |
|---------------------------------|--|--------------------|
| EWFA CERTIFICATE OF TEST | CERTIFICATE No : SFC 44065200.1 | Page 1 of 1 |
|---------------------------------|--|--------------------|

| Report Sponsor | Certificate Issue Date |
|--|------------------------|
| Tufftex 3 Hunt Street Malaga, WA, 6090 | 10/08/2017 |

Introduction

The element of construction described below was tested by this laboratory on behalf of the test sponsor in accordance with the stated test standard and achieved the results stated below. Refer to the referenced test report for more information.

| Referenced Report | Test Date | Test Standard |
|-------------------|------------|-----------------|
| EWFA 44065200.1 | 14/11/2016 | AS1530.8.1-2007 |



| Description of Product | | |
|-------------------------------|---|-----------------|
| Product name | Test Specimen Arrangement | Rating |
| 75mm TUFFWALL EPS cladding | <p>The specimen consisted of a nominal 3m x 3m timber stud framed wall system having a central area nominal 2m wide x 2.4m high offset 250mm back from the front face incorporating a sill and eaves details and an 800mm x 800mm aluminium framed window.</p> <p>The unexposed side was faced with 10mm Gyprock plasterboard while the exposed side had a nominally 8.7mm thick TUFF WALL acrylic render system applied over 75mm TUFFWALL EPS cladding system. Refer to the test report for a full description.</p> | BAL A-29 |

Notes

THIS CERTIFICATE IS PROVIDED FOR GENERAL INFORMATION ONLY AND DOES NOT COMPLY WITH THE REGULATORY REQUIREMENTS FOR EVIDENCE OF COMPLIANCE.

Reference should be made to the relevant test report to determine the applicability of the test result to a proposed installation and for a full description of the tested construction.

The results of these fire tests may be used to assess fire hazard, but it should be recognised that a single test method will not provide a full assessment of fire hazard under all conditions.

| | | |
|--------------------------|--|--|
| TESTING AUTHORITY | Exova Warringtonfire Aus Pty Ltd | |
| Address | PO Box 4282 DANDENONG SOUTH VIC 3164 Unit 2, 409-411 Hammond Road, DANDENONG VIC 3175 | |
| Phone | +61 (0) 3 9767 1000 | |
| ABN | 81 050 241 524 | |
| Email / Home Page | www.exova.com | |
| Authorisation | Prepared By:  Mandeep Kamal | Reviewed By:  Steven Halliday |